



Questions and Answers

Date: March 13, 2024

To: Interested Firms and Individuals

From: Evan Cai, Associate Engineer, Public Works Department

Subject: Q&A for the San Carlos Avenue Pedestrian Safety Improvement Project Phase III – C1806

**BID PROPOSALS ARE DUE TO THE CITY CLERK'S OFFICE NO LATER THAN
10:00 A.M. ON MARCH 19, 2024**

The City received the following questions (in bold) that were submitted through emails. Answers are in plain type below each question.

- 1. Bid Item 17 Remove Tree indicates 3 trees; however, Plan Sheets C2.1 – C2.3 indicates 4 tree removals. Please clarify how many trees are to be removed.**

The bid item should be 4 trees. Please refer to Addendum #01 for a revised bid schedule.

- 2. There are base repair areas shown on the plans, however there are no bid items for the work. How does the base repair get paid for?**

Asphalt Concrete Base Repair has been added as new Bid Item 109. Please refer to Addendum #01 for a revised bid schedule.

- 3. Bio Retention areas call for an Impermeable Liner. There are no bid items or method of payment for this work.**

Impermeable Liner is part of Base Bid Item 79 Bio-Treatment Permeable. Please refer to Addendum #01 for a revised bid item description.

- 4. Plans call for FDAC AC conform. There is an item for 2" mill but not for a conform mill.**

Removal beyond 2" mill to be covered by Bid Item 5 Remove AC.